

Water Sampling Table
 Gladstone High School
 18800 Portland Avenue
 Gladstone, Oregon
 April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/17/2016	W01A/W01A	Domestic Main Bubbler	Boiler Room	See 58A	See 58A	I	ND	35.0
6/17/2016	W01B/W01B	Domestic Main Bubbler	Boiler Room	See 58B	See 58B	F	ND	ND
6/17/2016	W02A	Sink	J102	0.098	3.1	I		
6/17/2016	W02B	Sink	J102	0.105	ND	F		
6/17/2016	W03A	Sink	J120	0.140	ND	I		
6/17/2016	W03B	Sink	J120	0.110	ND	F		
6/17/2016	W04A	Sink	J106 (HEALTH)	0.129	3.2	I		
6/17/2016	W04B	Sink	J106 (HEALTH)	0.099	ND	F		
6/17/2016	W05A	High Bubbler	Corridor by high Bubbler	0.060	ND	I		
6/17/2016	W05B	High Bubbler	Corridor by high Bubbler	0.079	ND	F		
6/17/2016	W06A	Low Bubbler	Corridor by high Bubbler	0.060	ND	F		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Gladstone High School
 18800 Portland Avenue
 Gladstone, Oregon
 April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/17/2016	W07A	High Bubbler	H104 Girl's Locker Room	0.163	2.6	I		
6/17/2016	W07B	High Bubbler	H104 Girl's Locker Room	0.098	ND	F		
6/17/2016	W08A	Low Bubbler	H104 Girl's Locker Room	0.302	ND	F		
6/17/2016	W09A	Bubbler	Room 112	0.163	ND	I		
6/17/2016	W09B	Bubbler	Room 112	0.114	ND	F		
6/17/2016	W10A	Sink	Snack Shop	0.057	ND	I		
6/17/2016	W10B	Sink	Snack Shop	0.204	ND	F		
6/17/2016	W11A	High Bubbler	Men's Locker Room	0.091	ND	I		
6/17/2016	W11B	High Bubbler	Men's Locker Room	0.083	ND	F		
6/17/2016	W12A	Low Bubbler	Men's Locker Room	0.096	ND	I		
6/17/2016	W13A	Bubbler	Men's Team Room	0.159	ND	I		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Gladstone High School
 18800 Portland Avenue
 Gladstone, Oregon
 April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/17/2016	W13B	Bubbler	Men's Team Room	0.101	ND	F		
6/17/2016	W14A	Sink	Student Store	0.110	ND	I		
6/17/2016	W14B	Sink	Student Store	0.074	ND	F		
6/17/2016	W15A	Bubbler	Cafeteria	ND	ND	I		
6/17/2016	W15B	Bubbler	Cafeteria	ND	ND	F		
6/17/2016	W16A	Bubbler	Corridor by G105	0.508	ND	I		
6/17/2016	W16B	Bubbler	Corridor by G105	0.354	ND	F		
6/17/2016	W17A	Sink	F108	0.144	ND	I		
6/17/2016	W17B	Sink	F108	0.098	ND	F		
6/17/2016	W18A	Sink	F11	0.098	7.9	I		
6/17/2016	W18B	Sink	F11	0.090	ND	F		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Gladstone High School
 18800 Portland Avenue
 Gladstone, Oregon
 April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/17/2016	W19A	High Bubbler	Corridor by G109	0.079	ND	I		
6/17/2016	W19B	High Bubbler	Corridor by G109	0.118	ND	F		
6/17/2016	W20A	Low Bubbler	Corridor by G109	0.093	ND	F		
6/17/2016	W21A	Sink	F103 Station #1	ND	3.4	I		
6/17/2016	W21B	Sink	F103 Station #1	0.091	ND	F		
6/17/2016	W22A	Sink	F103 Station #2	0.114	3.3	I		
6/17/2016	W22B	Sink	F103 Station #2	0.097	ND	F		
6/17/2016	W23A	Sink	F103 Station #3	0.106	ND	I		
6/17/2016	W23B	Sink	F103 Station #3	0.114	ND	F		
6/17/2016	W24A	Sink	F103 Station #4	0.108	ND	I		
6/17/2016	W24B	Sink	F103 Station #4	0.110	ND	F		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Gladstone High School
 18800 Portland Avenue
 Gladstone, Oregon
 April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/17/2016	W25A	Sink	F103 Station 5	0.112	5.0	I		
6/17/2016	W25B	Sink	F103 Station 5	0.200	ND	F		
6/17/2016	W26A	Sink	F103 Station 6	0.111	2.7	I		
6/17/2016	W26B	Sink	F103 Station 6	0.162	ND	F		
6/17/2016	W27A	Sink	By Washer	0.058	5.6	I		
6/17/2016	W27B	Sink	By Washer	0.075	ND	F		
6/17/2016	W28A	Sink	A113	0.087	3.5	I		
6/17/2016	W28B	Sink	A113	0.112	ND	F		
6/17/2016	W29A	Sink	D105	0.133	ND	I		
6/17/2016	W29B	Sink	D105	0.170	ND	F		
6/17/2016	W30A	Sink	Library	0.208	ND	I		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Gladstone High School
 18800 Portland Avenue
 Gladstone, Oregon
 April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/17/2016	W30B	Sink	Library	0.112	ND	F		
6/17/2016	W31A	Sink	B101 (SW Wall)	0.240	7.2	I		
6/17/2016	W31B	Sink	B101 (SW Wall)	0.215	ND	F		
6/17/2016	W32A	Sink	B101-Lab #7	0.130	42.2	I		
6/17/2016	W32B	Sink	B101-Lab #7	0.108	3.5	F		
6/17/2016	W33A	Sink	B102-Lab South	0.229	4.4	I		
6/17/2016	W33B	Sink	B102-Lab South	0.124	ND	F		
6/17/2016	W34A	Sink	B102-North	0.188	4.2	I		
6/17/2016	W34B	Sink	B102-North	0.122	ND	F		
6/17/2016	W35A	Sink	B103-North	0.172	2.5	I		
6/17/2016	W35B	Sink	B103-North	0.118	ND	F		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Gladstone High School
 18800 Portland Avenue
 Gladstone, Oregon
 April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/17/2016	W36A	Sink	B103-Southwest	0.143	40.4	I		
6/17/2016	W36B	Sink	B103-Southwest	0.146	3.9	F		
6/17/2016	W37A	Sink	B104	0.226	3.6	I		
6/17/2016	W37B	Sink	B104	0.147	ND	F		
6/17/2016	W38A	Sink	B105 North	0.138	ND	I		
6/17/2016	W38B	Sink	B105 North	0.128	ND	F		
6/17/2016	W39A	Sink	B105 South	0.180	4.1	I		
6/17/2016	W39B	Sink	B105 South	0.130	ND	F		
6/17/2016	W40A	Sink	B106	0.187	4.3	I		
6/17/2016	W40B	Sink	B106	0.215	ND	F		
6/17/2016	W41A	Sink	B106 Station #10-west	0.168	38.7	I		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Gladstone High School
 18800 Portland Avenue
 Gladstone, Oregon
 April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/17/2016	W41B	Sink	B106 Station #10-west	0.245	2.0	F		
6/17/2016	W42A	Sink	B104-East	0.087	42.4	I		
6/17/2016	W42B	Sink	B104-East	0.113	3.6	F		
6/17/2016	W43A	High Bubbler	Corridor by B113	0.255	ND	I		
6/17/2016	W43B	High Bubbler	Corridor by B113	0.202	ND	F		
6/17/2016	W44A	Low Bubbler	Corridor by B113	0.269	ND	F		
6/17/2016	W45A	Sink	B107	0.229	4.6	I		
6/17/2016	W45B	Sink	B107	0.238	ND	F		
6/17/2016	W46A	Sink	B109	0.221	4.2	I		
6/17/2016	W46B	Sink	B109	0.272	ND	F		
6/17/2016	W47A	Sink	B112	0.162	6.3	I		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Gladstone High School
 18800 Portland Avenue
 Gladstone, Oregon
 April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/17/2016	W47B	Sink	B112	0.166	ND	F		
6/17/2016	W48A	Sink	C134-East	0.161	ND	I		
6/17/2016	W48B	Sink	C134-East	0.146	ND	F		
6/17/2016	W49A	Sink	C134-West	0.121	ND	I		
6/17/2016	W49B	Sink	C134-West	0.161	ND	F		
6/17/2016	W50A	Sink	C129	0.175	ND	I		
6/17/2016	W50B	Sink	C129	0.148	ND	F		
6/17/2016	W51A	Sink	C123-Southwest	0.193	ND	I		
6/17/2016	W51B	Sink	C123-Southwest	0.148	ND	F		
6/17/2016	W52A	Sink	C123-North	0.159	ND	I		
6/17/2016	W52B	Sink	C123-North	0.154	ND	F		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Gladstone High School
 18800 Portland Avenue
 Gladstone, Oregon
 April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/17/2016	W53A	Sink	C123-East	0.124	7.2	I		
6/17/2016	W53B	Sink	C123-East	0.154	ND	F		
6/17/2016	W54A	Bubbler	Corridor by C117	0.244	ND	I		
6/17/2016	W54B	Bubbler	Corridor by C117	0.258	ND	F		
6/17/2016	W55A/W02A	Sink	C106	1.20	3.4	I	2.37	12.0
6/17/2016	W55B/W02B	Sink	C106	ND	2.2	F	0.058	8.0
6/17/2016	W56A	Bubbler	West Exterior	0.139	4.3	I		
6/17/2016	W56B	Bubbler	West Exterior	0.122	2.6	F		
6/20/2016	W57A	Bubbler	Shop	0.254	79.9	I		
6/20/2016	W57B	Bubbler	Shop	0.480	940.0	F		
6/20/2016	W58A	Sink	WTRM	0.105	ND	I		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Gladstone High School
 18800 Portland Avenue
 Gladstone, Oregon
 April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/20/2016	W58B	Sink	WTRM	0.067	ND	F		
6/20/2016	W59A	Sink	GYMS	ND	ND	I		
6/20/2016	W59B	Sink	GYMS	0.091	ND	F		
3/9/2018	W03AH	Fountain High	ATC Entry			I	0.080	ND
3/9/2018	W03AL	Fountain Low	ATC Entry			F	0.076	ND
3/9/2018	W03AF	Bottle Filler	Entry Fountain			I	0.067	ND
3/9/2018	W03B	Bottle Filler	Entry Fountain			F	ND	ND

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214