

Water Sampling Table
 Gladstone Center for Children and Families
 18905 Portland Ave
 Gladstone, Oregon 97027
 Updated April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/16/2016	W01A/W01A	Domestic Main	Mechanical Room	0.133	19.0	I	ND	3.0
6/16/2016	W01B/W01B	Domestic Main	Mechanical Room	ND	ND	F	ND	3.0
6/16/2016	W02A	Sink	Healthy Start	0.067	ND	I		
6/16/2016	W02B	Sink	Healthy Start	0.178	ND	F		
6/16/2016	W03A	High Sink	ESD 7	0.262	ND	I		
6/16/2016	W03B	High Sink	ESD 7	0.120	ND	F		
6/16/2016	W04A	Lower Sink	ESD 7	0.267	ND	I		
6/16/2016	W05A	Lower Sink	ESD 8	0.207	ND	I		
6/16/2016	W05B	Lower Sink	ESD 8	0.126	ND	F		
6/16/2016	W06A	High Sink	ESD 8	0.126	4.2	I		
6/16/2016	W07A	Bubbler	ESD 8	0.227	ND	I		
6/16/2016	W08A	High Sink	Head Start 9	0.232	ND	I		
6/16/2016	W08B	High Sink	Head Start 9	0.346	ND	F		
6/16/2016	W09A	Low Sink	Head Start 9	0.268	ND	I		
6/16/2016	W10A	Low Sink	Head Start 10	0.253	ND	I		
6/16/2016	W10B	Low Sink	Head Start 10	0.243	ND	F		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Water Sampling Table
 Gladstone Center for Children and Families
 18905 Portland Ave
 Gladstone, Oregon 97027
 Updated April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/16/2016	W11A	High Sink	Head Start 10	0.206	ND	I		
6/16/2016	W12A	Sink	Main Office Northeast Room	0.261	ND	I		
6/16/2016	W12B	Sink	Main Office Northeast Room	0.139	ND	F		
6/16/2016	W13A	Sink	Main Office South Central Room	0.287	ND	I		
6/16/2016	W13B	Sink	Main Office South Central Room	0.275	ND	F		
6/16/2016	W14A	High Bubblers	South Hall Drinking Fountains	0.357	ND	I		
6/16/2016	W14B	High Bubblers	South Hall Drinking Fountains	0.144	ND	F		
6/16/2016	W15A	Low Bubblers	South Hall Drinking Fountains	0.161	ND	I		
6/16/2016	W16A	Sink	Bathroom Near Kitchen	0.150	4.9	I		
6/16/2016	W16B	Sink	Bathroom Near Kitchen	0.141	ND	F		
6/16/2016	W17A	Sink	Kitchen Sink Area East Wall 1	0.213	ND	I		
6/16/2016	W17B	Sink	Kitchen Sink Area East Wall 1	0.142	ND	F		
6/16/2016	W18A	Sink	Kitchen Sink Area East Wall 1	0.124	ND	I		
6/16/2016	W18B	Sink	Kitchen Sink Area South Wall 1	0.051	ND	F		
6/16/2016	W19A	Sink	Kitchen Sink Area South Wall 2	0.147	ND	I		
6/16/2016	W19B	Sink	Kitchen Sink Area South Wall 2	0.050	ND	F		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Water Sampling Table
 Gladstone Center for Children and Families
 18905 Portland Ave
 Gladstone, Oregon 97027
 Updated April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/16/2016	W20A	Sink	Kitchen Sink Area North Wall 1	0.224	ND	I		
6/16/2016	W20B	Sink	Kitchen Sink Area North Wall 1	ND	ND	F		
6/16/2016	W21A	Sink	Kitchen Sink Area North Wall 2	0.286	ND	I		
6/16/2016	W21B	Sink	Kitchen Sink Area North Wall 2	ND	ND	F		
6/16/2016	W22A	Sink	Kitchen Sink Area East Wall 2	0.110	ND	I		
6/16/2016	W22B	Sink	Kitchen Sink Area East Wall 2	0.156	ND	F		
6/16/2016	W23A	Bubbler	Kindergarten 6	0.235	ND	I		
6/16/2016	W23B	Bubbler	Kindergarten 6	0.219	ND	F		
6/16/2016	W24 A	Low Sink	Kindergarten 6	0.198	ND	I		
6/16/2016	W25A	High Sink	Kindergarten 6	0.242	ND	I		
6/16/2016	W26A	High Sink	Kindergarten 5	0.257	ND	I		
6/16/2016	W26B	High Sink	Kindergarten 5	0.145	ND	F		
6/16/2016	W27A	Low Sink	Kindergarten 5	0.189	ND	I		
6/16/2016	W28A	Bubbler	Kindergarten 5	0.152	ND	I		
6/16/2016	W29A	Low Sink	Kindergarten 4	0.249	ND	I		
6/16/2016	W29B	Low Sink	Kindergarten 4	0.264	ND	F		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Water Sampling Table
 Gladstone Center for Children and Families
 18905 Portland Ave
 Gladstone, Oregon 97027
 Updated April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/16/2016	W30A	Bubbler	Kindergarten 4	0.215	ND	I		
6/16/2016	W31A	High Sink	Kindergarten 4	0.214	ND	I		
6/16/2016	W32A	Lower Bubbler	Outside North Bathrooms	0.178	ND	I		
6/16/2016	W32B	Low Bubbler	Outside North Bathrooms	0.151	ND	F		
6/16/2016	W33A	Low Bubbler	Outside North Bathrooms	0.205	ND	I		
6/16/2016	W34A	Bubbler	Kindergarten 3	0.327	ND	I		
6/16/2016	W34B	Bubbler	Kindergarten 3	0.324	ND	F		
6/16/2016	W35A	Low Sink	Kindergarten 3	0.304	ND	I		
6/16/2016	W36A	High Sink	Kindergarten 3	0.318	ND	I		
6/16/2016	W37A	Low Sink	Kindergarten 2	0.318	ND	I		
6/16/2016	W37B	Low Sink	Kindergarten 2	0.366	ND	F		
6/16/2016	W38A	Bubbler	Kindergarten 2	0.395	ND	I		
6/16/2016	W39A	High Sink	Kindergarten 2	0.356	ND	I		
6/16/2016	W40A	Bubbler	Kindergarten 1	0.406	ND	I		
6/16/2016	W40B	Bubbler	Kindergarten 1	0.365	ND	F		
6/16/2016	W41A	Low Sink	Kindergarten 1	0.334	ND	I		

Bold-Indicates Exceeds Action Level

EPA Action Levels

Copper 1.3 mg/L

Lead 15 parts per billion

Kelsay Environmental

833 SE Main St., Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Gladstone Center for Children and Families
 18905 Portland Ave
 Gladstone, Oregon 97027
 Updated April 12, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/16/2016	W42A	High Sink	Kindergarten 1	0.376	ND	I		
3/9/2018	W02A	Fountain Bottle Filler	Hallway			I	ND	ND
3/9/2018	W02B	Fountain Bottle Filler	Hallway			F	ND	ND

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St., Suite 410
 Portland, Oregon 97214