



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 03/22/2018  
Received: 03/09/2018  
Sampled By: Mitchel Elliot/Keith K  
Work Order: 8068040

**C**  
**L**  
**I**  
**E**  
**N**  
**T**  
**Kelsay Environmental**  
Attn: -  
833 SE Main St Ste 410  
Portland OR, 97214  
Phone: (503) 705-0514

**Project:**  
Project # : 3013.00  
Sample Type :

Sampling Location: Gladstone Center for Children and Families (GCCF)

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL *	Analysis Date/ Time
<b>8068040-01</b>	<b>Sample Name:</b> 3013.00 - WO1A Domestic Main <b>Sampled:</b> 3/9/18 8:10						<b>Matrix:</b> Water
†Copper	1055	SM3111B	ND	mg/L	0.050	1.3 mg/L	03/20/18 14:32
†Lead	1030	EPA 200.9	3	ppb	2	20 ppb	03/21/18 14:57
<b>8068040-02</b>	<b>Sample Name:</b> 3013.00 - WO1B Domestic Main <b>Sampled:</b> 3/9/18 8:10						<b>Matrix:</b> Water
†Copper	1055	SM3111B	ND	mg/L	0.050	1.3 mg/L	03/20/18 14:32
†Lead	1030	EPA 200.9	3	ppb	2	20 ppb	03/21/18 14:57
<b>8068040-03</b>	<b>Sample Name:</b> 3013.00 - WO2A Hallway Fountain Bottle Filler <b>Sampled:</b> 3/9/18 8:17						<b>Matrix:</b> Water
†Copper	1055	SM3111B	ND	mg/L	0.050	1.3 mg/L	03/20/18 14:32
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/21/18 14:57
<b>8068040-04</b>	<b>Sample Name:</b> 3013.00 - WO2B Hallway Fountain Bottle Filler <b>Sampled:</b> 3/9/18 8:17						<b>Matrix:</b> Water
†Copper	1055	SM3111B	ND	mg/L	0.050	1.3 mg/L	03/20/18 14:32
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/21/18 14:57

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director

