



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 03/22/2018
Received: 03/09/2018
Sampled By: Mitchel Elliot/Keith K
Work Order: 8068038

C **Kelsay Environmental**
L Attn: -
I 833 SE Main St Ste 410
E Portland OR, 97214
N
T Phone: (503) 705-0514

Project:
Project # : 3011.00
Sample Type :

Sampling Location: John Wetten Elementary

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
8068038-01	Sample Name: 3011.00 - WO1A Vice Principal Office Sink Sampled: 3/9/18 8:43						Matrix: Water
†Copper	1055	SM3111B	0.121	mg/L	0.050	1.3 mg/L	03/20/18 14:32
†Lead	1030	EPA 200.9	2	ppb	2	20 ppb	03/21/18 14:57
8068038-02	Sample Name: 3011.00 - WO1B Vice Principal Office Sink Sampled: 3/9/18 8:43						Matrix: Water
†Copper	1055	SM3111B	ND	mg/L	0.050	1.3 mg/L	03/20/18 14:32
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/21/18 14:57

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

