



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 03/29/2018  
Received: 03/21/2018  
Sampled By: Keith Kilcoin  
Work Order: 8082029

**C** **Kelsay Environmental**  
**L** Attn: -  
**I** 833 SE Main St Ste 410  
**E** Portland OR, 97214  
**N** Phone: (503) 705-0514  
**T**

**Project:** Gladstone  
**Project # :** N/A  
**Sample Type :**

Sampling Location: John Wetten Elementary

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>8082029-01</b>	<b>Sample Name:</b> W01A - John Wetten Room 5 <b>Sampled:</b> 3/16/18 7:15						<b>Matrix:</b> Water
+Copper	1055	SM3111B	0.049	mg/L	0.020	1.3 mg/L	03/28/18 14:36
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/28/18 13:12
<b>8082029-02</b>	<b>Sample Name:</b> W01B - John Wetten Room 5 <b>Sampled:</b> 3/16/18 7:15						<b>Matrix:</b> Water
+Copper	1055	SM3111B	0.033	mg/L	0.020	1.3 mg/L	03/28/18 14:36
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/28/18 13:12
<b>8082029-03</b>	<b>Sample Name:</b> W02A - John Wetten Resource <b>Sampled:</b> 3/16/18 7:15						<b>Matrix:</b> Water
+Copper	1055	SM3111B	0.134	mg/L	0.020	1.3 mg/L	03/28/18 14:36
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/28/18 13:12
<b>8082029-04</b>	<b>Sample Name:</b> W02B - John Wetten Resource <b>Sampled:</b> 3/16/18 7:15						<b>Matrix:</b> Water
+Copper	1055	SM3111B	0.098	mg/L	0.020	1.3 mg/L	03/28/18 14:36
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/28/18 13:12

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director



Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 8082029-01-04

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

<b>Client Contact Information</b>	<b>Results Reporting Information</b>	<b>Invoicing Information</b>
Company/Client Name: <u>Kellogg Environmental</u>	Project Manager:	Accounts Payable Contact:
Address: <u>833 SE Main Street</u>	Mailing Address:	Mailing Address:
City/State/Zip: <u>Portland, OR 97214</u>	City/State/Zip:	City/State/Zip:
phone: <u>503-978-6844</u>	phone:	phone:
fax or email:	fax or email:	fax or email:

**SAMPLING INFORMATION**

Sampling Location: Top of the Hill Elementary P.O. #: \_\_\_\_\_

Sampled By: Kellogg Environmental Project Name: Chadstone Project #: \_\_\_\_\_

Send results to OR State Health Division? (Please circle) Yes  No  Permit #: \_\_\_\_\_

Lab ID	Sample Identification	Date Collected	Time Collected (Begin/End if camp)	Sample Matrix*	# of cont. rec'd	Analysis Requested**	Sample Specific Notes/Field Data for each WW sample, specify <u>Grab / Composite</u> for each DW sample, specify <u>Raw / Treated</u> . <u>Source / Distribution Single / Combined</u> WHERE APPLICABLE
-01	u0118 - John Nelson Room 5	3/6/18	7:15				
-02	u0218 - " "						
-03	u0318 - John Nelson - Resource?						
-04	u0418 - " "						

Relinquished By (print): Kellogg Environmental Company: \_\_\_\_\_ Date/Time: \_\_\_\_\_ Signature: \_\_\_\_\_

Relinquished By (print): Kellogg Environmental Company: \_\_\_\_\_ Date/Time: \_\_\_\_\_ Signature: \_\_\_\_\_

Received By: \_\_\_\_\_ Company: \_\_\_\_\_ Date/Time: \_\_\_\_\_ Signature: \_\_\_\_\_

Received By: \_\_\_\_\_ Company: \_\_\_\_\_ Date/Time: \_\_\_\_\_ Signature: \_\_\_\_\_

Temp. on receipt: \_\_\_\_\_ °C On ice?  Y  N

Containers Intact?  Y  N ID: TRM-10- \_\_\_\_\_

Received by Laboratory Log-In Staff: STP Date/Time: 3/21/18

\* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

\*\* Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

COC-90-006rev0.1