

Water Sampling Table
 Kraxberger Middle School
 17777 Webster Road
 Gladstone, Oregon 97027
 Updated April 10, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	UpdatedLEAD ppb EPA MCL: 15
6/16/2016	W01A	Domestic Main	Kitchen Staff Bathroom	ND	ND	I		
6/16/2016	W01B	Domestic Main	Kitchen Staff Bathroom	ND	ND	F		
6/16/2016	W02A	Sink	Kitchen Back	0.062	3.5	I		
6/16/2016	W02B	Sink	Kitchen Back	ND	ND	F		
6/16/2016	W03A/W04AM	Main Sink	Kitchen	ND	ND	I	ND	ND
6/16/2016	W03B/W04BM	Main Sink	Kitchen	ND	ND	I	ND	ND
6/16/2016	W04A/W04AS	Sprayer	Kitchen	ND	3.1	I	ND	ND
6/16/2016	W04B/W05B	Sprayer	Kitchen	ND	ND	F		
6/16/2016	W05A	Sink	Faculty Lounge	0.079	ND	I		
6/16/2016	W05B	Sink	Faculty Lounge	0.065	ND	F		
6/16/2016	W06A/W01A	Sink	Nurse Room	0.070	14.6	I	0.091	ND
6/16/2016	W06B/W01B	Sink	Nurse Room	ND	ND	F	0.056	ND
6/16/2016	W07A	Sink	Room 7	ND	12.1	I		
6/16/2016	W08A	Bubbler	Room 7	ND	2.0	I		
6/16/2016	W07B	Sink	Room 7	ND	ND	F		
6/16/2016	W09A	Sink	Room 8	ND	12.0	I		
6/16/2016	W10A	Bubbler	Room 8	ND	8.6	I		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Kraxberger Middle School
 17777 Webster Road
 Gladstone, Oregon 97027
 Updated April 10, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/16/2016	W10B	Sink	Room 8	ND	4.0	F		
6/16/2016	W11A	Steel Sink	Room 10	ND	2.7	I		
6/16/2016	W11B	Steel Sink	Room 10	ND	ND	F		
6/16/2016	W12A	Porcelain Sink	Room 10	ND	5.1	I		
6/16/2016	W12B	Porcelain Sink	Room 10	ND	ND	F		
6/16/2016	W13A	Bubbler	Hallway across from room 9	0.068	ND	I		
6/16/2016	W13B	Bubbler	Hallway across from room 9	ND	ND	F		
6/16/2016	W14A	Sink	Room 9	0.168	19.1	I		
6/16/2016	W15A	Bubbler	Room 9	ND	2.6	I		
6/16/2016	W14B	Sink	Room 9	ND	ND	F		
6/16/2016	W16A	Sink	Room 11	ND	8.8	I		
6/16/2016	W17A	Bubbler	Room 11	ND	ND	I		
6/16/2016	W16B	Sink	Room 11	ND	ND	F		
6/16/2016	W18A	Sink	Room 14	ND	8.3	I		
6/16/2016	W19A	Bubbler	Room 14	ND	ND	I		
	W18B	Sink	Room 14	ND	ND	F		
6/16/2016	W20A	Bubbler	Hallway at Room 16	ND	ND	I		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Kraxberger Middle School
 17777 Webster Road
 Gladstone, Oregon 97027
 Updated April 10, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/16/2016	W20B	Bubbler	Hallway at Room 16	ND	ND	F		
6/16/2016	W21A	Sink	Room 16	ND	20.3	I		
6/16/2016	W22A	Bubbler	Room 16	ND	91.1	F		
6/16/2016	W21B	Sink	Room 16	ND	ND	F		
6/16/2016	W23A	Sink	Room 15	ND	12.8	I		
6/16/2016	W24A	Bubbler	Room 15	ND	ND	I		
6/16/2016	W23B	Sink	Room 15	ND	ND	F		
6/16/2016	W25A	Sink	Room 13	ND	8.3	I		
6/16/2016	W26A	Bubbler	Room 13	ND	ND	I		
6/16/2016	W25B	Sink	Room 13	ND	ND	F		
6/16/2016	W27A/W02A	Sink	Room 27	ND	10.2	I	ND	14.0
6/16/2016	W27B/W02B	Sink	Room 27	ND	ND	F	ND	ND
6/16/2016	W28A	Sink	Delgado Room	ND	12.6	I		
6/16/2016	W28B	Sink	Delgado Room	ND	ND	F		
6/16/2016	W29A	Bubbler	Hallway outside Delgado Room	0.138	ND	I		
6/16/2016	W29B	Bubbler	Hallway outside Delgado Room	ND	ND	F		
6/16/2016	W30A	Sink 1	Art Room	ND	3.7	I		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Kraxberger Middle School
 17777 Webster Road
 Gladstone, Oregon 97027
 Updated April 10, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/16/2016	W30B	Sink 1	Art Room	ND	ND	F		
6/16/2016	W31A	Sink 2	Art Room	ND	2.5	I		
6/16/2016	W031B	Sink 2	Art Room	ND	ND	F		
6/16/2016	W32A	Sink 3	Art Room	ND	3.3	I		
6/16/2016	W32B	Sink 3	Art Room	ND	ND	F		
6/16/2016	W33A	Sink	Room 26	ND	4.3	I		
6/16/2016	W33B	Sink	Room 26	ND	ND	F		
6/16/2016	W34A	Sink	Room 24	ND	ND	I		
6/16/2016	W35A	Bubbler	Room 24	ND	8.7	I		
6/16/2016	W34B	Sink	Room 24	ND	4.0	F		
6/16/2016	W36A	Bubbler	Cafeteria	0.129	ND	I		
6/16/2016	W36B	Bubbler	Cafeteria	0.094	7.9	F		
6/16/2016	W37A	Bubbler	Cafeteria (filter)	0.125	ND	I		
6/16/2016	W37B	Bubbler	Cafeteria (filter)	0.117	ND	F		
6/16/2016	W38A	Science Sink 1	Room 23	ND	99.7	I		
6/16/2016	W38B	Science Sink 1	Room 23	ND	5.5	F		
6/16/2016	W39A	Science Sink 2	Room 23	0.425	31.6	I		

Bold-Indicates Exceeds Action Level

EPA Action Levels

Copper 1.3 mg/L

Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Kraxberger Middle School
 17777 Webster Road
 Gladstone, Oregon 97027
 Updated April 10, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	Updated LEAD ppb EPA MCL: 15
6/16/2016	W39B	Science Sink 2	Room 23	0.170	22.9	F		
6/16/2016	W40A	Science Sink 1	Room 22	0.080	15.8	I		
6/16/2016	W40B	Science Sink 1	Room 22	0.074	ND	F		
6/16/2016	W41A	Science Sink 2	Room 22	0.067	4.7	I		
6/16/2016	W41B	Science Sink 2	Room 22	ND	ND	F		
6/16/2016	W42A	Science Sink 1	Room 21	0.261	33.7	I		
6/16/2016	W42B	Science Sink 1	Room 21	ND	ND	F		
6/16/2016	W43A	Science Sink 2	Room 21	0.102	8.9	I		
6/16/2016	W43B	Science Sink 2	Room 21	0.135	ND	F		
6/16/2016	W44A	High Fountain	Outside Gym	0.112	ND	I		
6/16/2016	W45A	Low Fountain	Outside Gym	0.086	ND	I		
6/16/2016	W45B	Low Fountain	Outside Gym	ND	ND	F		
6/16/2016	W46A	Bubbler	Inside Gym	0.142	ND	I		
6/16/2016	W46B	Bubbler	Inside Gym	0.139	ND	F		
6/16/2016	W47A	High Bubbler	Gym 1	ND	ND	I		
6/16/2016	W48A	Low Bubbler	Gym 1	ND	ND	I		
6/16/2016	W48B	Low Bubbler	Gym 1	ND	ND	F		

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214

Water Sampling Table
 Kraxberger Middle School
 17777 Webster Road
 Gladstone, Oregon 97027
 Updated April 10, 2018

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	COPPER mg/L EPA MCL: 1.3	LEAD ppb EPA MCL: 15	Intital (I) or Follow Up Draw (F)	Updated COPPER mg/L EPA MCL: 1.3	UpdatedLEAD ppb EPA MCL: 15
6/16/2016	W49A	Sink	Boy's Locker Room	ND	7.7	I		
6/16/2016	W49B	Sink	Boy's Locker Room	ND	3.2	F		
6/16/2016	W50A	Sink	Office in Library	0.089	85.5	I		
6/16/2016	W50B	Sink	Office in Library	ND	2.3	F		
6/16/2016	W51A	Sink	Library AV Room	0.066	65.3	I		
6/16/2016	W51B	Sink	Library AV Room	ND	2.9	F		
6/16/2016	W52A	Bubbler	Choir Room	0.057	5.7	I		
6/16/2016	W52B	High Sink	Choir Room	0.053	ND	I		
6/16/2016	W53A	High Sink	Choir Room	ND	2.8	F		
6/24/2016	W01A/W 05A	Sprayer Sink	Kitchen	0.132	22.0	I	0.155	70.0
6/24/2016	W01B/W 05B	Sprayer Sink	Kitchen	ND	9.3	F	ND	16.0
3/9/2018	W03A	Sink	Room 29			I	ND	23.0
3/9/2018	W03B	Sink	Room 29			F	ND	ND
3/9/2018	W06A	Dishwasher Sprayer	Kitchen			I	ND	3.0
3/9/2018	W05B	Dishwasher Sprayer	Kitchen			F	ND	ND
3/9/2018	W03A	Room 29	Sink			I	ND	23.0
3/9/2018	W03B	Room 29	Sink			F	ND	ND

Bold-Indicates Exceeds Action Level
 EPA Action Levels
 Copper 1.3 mg/L
 Lead 15 parts per billion

Kelsay Environmental

833 SE Main St. Suite 410
 Portland, Oregon 97214