



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/07/2022
Received: 06/13/2022
Sampled By: David Lang
Work Order: 2165002

C
L
I
E
N
T
Kelsay Environmental
Attn: Brad Kelsay
833 SE Main St Ste 410
Portland OR, 97214
Phone: (503) 705-0514

Project:
Project # : 17777
Sample Type :

Sampling Location: Kraxberger / District office

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2165002-01	Sample Name: 19310300 - 076CF Sampled: 6/11/22 0:00		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	07/05/22 15:51
2165002-02	Sample Name: 19310100 - 001BF Sampled: 6/11/22 0:00		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	9	ppb	1	15 ppb	07/05/22 15:51
2165002-03	Sample Name: 19310100 - 002BF Sampled: 6/11/22 0:00		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	07/05/22 15:51
2165002-04	Sample Name: 19310100 - 003KF Sampled: 6/11/22 0:00		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/05/22 15:51
2165002-05	Sample Name: 19310100 - 004OT Sampled: 6/11/22 0:00		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/05/22 15:51


ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director



Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 2165002-016-05

Page 1 of 1

13035 SW Pacific Hwy Tigard, OR 97223 ph. 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Kelsay Environmental	Project Manager: Brad Kelsay	Accounts Payable Contact:
Address: 833 Se Main St. Suite 410	Mailing Address: same	Mailing Address:
City/State/Zip: Portland, OR 97214	City/State/Zip:	City/State/Zip:
phone: 503 705-0514	phone:	phone:
fax or email: bradkelsay@comcast.net	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Kaxberger / District office P.O. #: _____

Sampled By: David Lang Project Name: _____ Project #: 17777 Permit #: _____

Send results to OR State Health Division? (Please circle) Yes No

Please send pdf + csv files

Lab ID	Sample Identification	Date Collected	Time Collected	Sample Matrix*	# of cont. rec'd	Analysis Requested**	Signature
01	19310300-076 CF	6/11		DW	Y		
02	19310100-001BF				X		
03	19310100-002BF				X		
04	19310100-003KF				X		
05	19310100-004OT				X		

SEE ATTACHED

Sample Specific Notes/Field Data for each WW sample, specify Grab / Composite for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE

Relinquished By (print): David Lang Company: Kelsay Env. Date/Time: 6/11 Signature: [Signature]

Relinquished By (print): _____ Company: _____ Date/Time: _____ Signature: _____

Received By: _____ Date/Time: _____ Signature: _____

Received By: _____ Date/Time: _____ Signature: _____

Temp. on receipt: — °C On ice? Y

Containers intact? 8 N ID: TRM-10-

The most current revision of SOP-10-003 was used when these samples were collected

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)