



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/12/2022
Received: 06/16/2022
Sampled By: DAVID Lang
Work Order: 2167032

C
L
I
E
N
T
Kelsay Environmental
Attn: Brad Kelsay/Lisa Janik
833 SE Main St Ste 410
Portland OR, 97214
Phone: (503) 705-0514

Project:
Project # : N/A
Sample Type :

Sampling Location: John Wetten Elementary School

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
2167032-01	Sample Name: 19310200 - 099DW Sampled: 6/16/22 0:00							Matrix: Water
+Lead	1030	EPA 200.9	9	ppb	1	15 ppb	07/11/22 17:02	
2167032-02	Sample Name: 19310200 - 100CF Sampled: 6/16/22 0:00							Matrix: Water
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	07/11/22 17:02	
2167032-03	Sample Name: 19310200 - 093CF Sampled: 6/16/22 0:00							Matrix: Water
+Lead	1030	EPA 200.9	10	ppb	1	15 ppb	07/11/22 17:02	
2167032-04	Sample Name: 19310200 - 094DW Sampled: 6/16/22 0:00							Matrix: Water
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	07/11/22 17:02	
2167032-05	Sample Name: 19310200 - 087CF Sampled: 6/16/22 0:00							Matrix: Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	07/11/22 17:02	
2167032-06	Sample Name: 19310200 - 088DW Sampled: 6/16/22 0:00							Matrix: Water
+Lead	1030	EPA 200.9	8	ppb	1	15 ppb	07/11/22 17:02	
2167032-07	Sample Name: 19310200 - 084DW Sampled: 6/16/22 0:00							Matrix: Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/11/22 17:02	
2167032-08	Sample Name: 19310200 - 083DW Sampled: 6/16/22 0:00							Matrix: Water
+Lead	1030	EPA 200.9	8	ppb	1	15 ppb	07/11/22 17:02	
2167032-09	Sample Name: 19310200 - 086BF Sampled: 6/16/22 0:00							Matrix: Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/11/22 17:02	
2167032-10	Sample Name: 19310200 - 085BF Sampled: 6/16/22 0:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/11/22 17:02	



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/12/2022
Received: 06/16/2022
Sampled By: DAVID Lang
Work Order: 2167032

CLIENT
Kelsay Environmental
Attn: Brad Kelsay/Lisa Janik
833 SE Main St Ste 410
Portland OR, 97214
Phone: (503) 705-0514

Project:
Project #: N/A
Sample Type:

Sampling Location: John Wetten Elementary School

Lab Number

Table with 8 columns: Lab Number, Code, Method, Result, Units, MRL, EPA MCL*, Analysis Date/ Time. Contains three rows of data for lead analysis (2167032-11, 2167032-12, 2167032-13).

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: [Signature]
Adriana Gonzalez-Gray
Laboratory Director



Professional Analytical Laboratory Services

Chain of Custody Record

Laboratory Job Number: 210 7092-01 to-10

Page 1 of 2

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Kelsay Environmental	Project Manager: Brad Kelsay	Accounts Payable Contact:
Address: 833 Se Main St. Suite 410	Mailing Address: same	Mailing Address:
City/State/Zip: Portland, OR 97214	City/State/Zip:	City/State/Zip:
phone: 503 705-0514	phone:	phone:
fax or email: bradkelsay@comcast.net	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: John Wether Elementary P.O. #: _____

Sampled By: David Lang Project Name: _____ Project #: _____

Send results to OR State Health Division? (Please circle) Yes No Permit #: _____

Please send CSV + pdf files

Lab ID	Sample Identification	Date Collected	Time Collected	Sample Matrix*	# of cont. rec'd	Analysis Requested**	SEE ATTACHED
G1	19310200 - 049 DW	6/16		DW	X		
O2	19310200 - 100 CF				X		
O3	19310200 - 093 CF				X		
O4	19310200 - 094 DW				X		
O5	19310200 - 087 CF				X		
O6	19310200 - 088 DW				X		
O7	19310200 - 084 DW				X		
O8	19310200 - 083 DW				X		
O9	19310200 - 086 BF				X		
O10	19310200 - 085 BF				X		

Reinforced By (print): David Lang Company: Kelsay Env Date/Time: 6/16 Signature: [Signature]


Relinquished By (print): _____ Company: _____ Date/Time: _____ Signature: _____

The most current revision of SOP-10-003 was used when these samples were collected

Received by Laboratory Log-In Staff: [Signature] Date/Time: 6/16/12 Temp. on receipt: 1576 °C On ice? Y

Containers Intact? N ID: TRM-10-_____

Sample Specific Notes/Field Data for each WW sample, specify **Grab / Treated**, for each DW sample, specify **Raw / Treated**, **Source / Distribution, Single / Combined** WHERE APPLICABLE



Alexin Analytical Laboratories, Inc.
Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 2167032

46-13

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

Page 2 of 2

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name:	Project Manager:	Accounts Payable Contact:
Address:	Mailing Address:	Mailing Address:
City/State/Zip:	City/State/Zip:	City/State/Zip:
phone:	phone:	phone:
fax or email:	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: John Wether Elementary P.O. #: _____ PWSID #: _____
 Sampled By: David Lang Project Name: _____ Project #: _____ Permit #: _____
 Send results to OR State Health Division? (Please circle) Yes No

Lab ID	Sample Identification	Please enter a unique ID per line for each separate sample	Date Collected	Time Collected (Begin/End if comp.)	Sample Matrix*	# of cont. rec'd	Analysis Requested**			Sample Specific Notes/Field Data for each WW sample, specify <u>Grab</u> / <u>Composite</u> for each DW sample, specify <u>Raw</u> / <u>Treated</u> , <u>Source</u> / <u>Distribution</u> , <u>Single</u> / <u>Combined</u> WHERE APPLICABLE	
							SEE ATTACHED				
<u>11</u>	<u>19310208-0552W</u>		<u>6/16</u>		<u>ow</u>		<u>X</u>	<u>X</u>	<u>X</u>		
<u>12</u>	<u>19310208-040DW</u>										
<u>13</u>	<u>19310208-041OW</u>										
Relinquished By (print): <u>David Lang</u>	Company: <u>Wether Sch</u>	Date/Time: <u>6/16</u>	Signature: <u>[Signature]</u>	Received By: _____	Company: _____	Date/Time: _____	Signature: _____	Received By: _____	Company: _____	Date/Time: _____	Signature: _____
Relinquished By (print): _____	Company: _____	Date/Time: _____	Signature: _____	Received By: _____	Company: _____	Date/Time: _____	Signature: _____	Received By: _____	Company: _____	Date/Time: _____	Signature: _____

The most current revision of SOP-10-003 was used when these samples were collected

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

Received by Laboratory Log-In Staff: [Signature] Date/Time: 6/16/12 Temp. on receipt: 15°C On ice? Y N ID: TRM-10----

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

COC-90-006rev0.1