

Kraxberger Middle School
Water Sampling Tables

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15
6/4/2022	19310300 - 001BF	Bathroom Faucet	Cafeteria, NE end	8
6/4/2022	19310300 - 002SF	Staff/Office Faucet	Kitchen, near dishwashing sink	2
6/4/2022	19310300 - 003OT	Dishwashing Sink	Kitchen dishwashing sink, NW end	11
6/4/2022	19310300 - 004OT	Sprayer	Kitchen sink hand sprayer, E wall	1
6/4/2022	19310300 - 005KF	Sink	Kitchen faucet, E wall	ND
6/4/2022	19310300 - 006IM	Ice Machine	Kitchen ice machine, E wall	ND
6/4/2022	19310300 - 007DW	Bubbler	Cafeteria water fountain, E end	ND
6/4/2022	19310300 - 008WB	Bottle Filler	Cafe bottle filler, E end	ND
6/4/2022	19310300 - 009BF	Bathroom Faucet	Hallway between Gym 1 & Library, E end	2
6/4/2022	19310300 - 010BF	Bathroom Faucet	Hallway between Gym 1 & Library, center hallway	ND
6/4/2022	19310300 - 011DW	Bubbler	Hallway between Gym 1 & Library, W end hallway	ND
6/4/2022	19310300 - 012DW	Bubbler	Hallway between Gym 1 & Library, W end hallway	ND
6/4/2022	19310300 - 013SF	Sink	Library office, W wall	55
6/4/2022	19310300 - 014BF	Bathroom Faucet	Girls locker room, N end	7
6/4/2022	19310300 - 015BF	Bathroom Faucet	Girls locker room, N end	8
6/4/2022	19310300 - 016DW	Bubbler	Choir room, NW corner	8
6/4/2022	19310300 - 017CF	Classroom Faucet	Choir room, NW corner	7
6/4/2022				
6/4/2022	19310300 - 019BF	Bathroom Faucet	Boys locker room, N end	4
6/4/2022	19310300 - 020DW	Bubbler	Gym 2, NE corner	1
6/4/2022	19310300 - 021DW	Bubbler	Hallway outside of room 21	ND
6/4/2022	19310300 - 022DW	Bubbler	Hallway outside of room 21	ND
6/4/2022	19310300 - 023CF	Classroom Faucet	Classroom 24	99
6/4/2022	19310300 - 024DW	Bubbler	Classroom 24	7
6/4/2022	19310300 - 025CF	Classroom Faucet	Classroom 26	20
6/4/2022	19310300 - 026CF	Classroom Faucet	Classroom 28, SE	4
6/4/2022	19310300 - 027CF	Classroom Faucet	Classroom 28, NE	2
6/4/2022	19310300 - 028CF	Classroom Faucet	Classroom 28, SE	8

Kraxberger Middle School
Water Sampling Tables

6/4/2022	19310300 - 029WB	Bottle Filler	Hallway outside of room 29	ND
6/4/2022	19310300 - 030DW	Bubbler	Hallway outside of room 29	ND
6/4/2022	19310300 - 031CF	Classroom Faucet	Classroom 29 W Wall	13
6/4/2022	19310300 - 032CF	Classroom Faucet	Classroom 27 W Wall	11
6/4/2022	19310300 - 033BF	Bathroom Faucet	Bathroom, N of room 22	51
6/4/2022	19310300 - 034BF	Bathroom Faucet	Bathroom Girls, N of room 9	4
6/4/2022	19310300 - 035CF	Sink	Classroom 9 East Wall	4
6/4/2022	19310300 - 036DW	Bubbler	Classroom 9 East Wall	2
6/4/2022	19310300 - 037BF	Bathroom Faucet	Bathroom Girls, N of room 9	38
6/4/2022	19310300 - 038CF	Classroom Faucet	Classroom 13, East Wall	32
6/4/2022	19310300 - 039DW	Bubbler	Classroom 13, East Wall	4
6/4/2022	19310300 - 040CF	Classroom Faucet	Classroom 15, East Wall	18
6/4/2022	19310300 - 041DW	Bubbler	Classroom 15, East Wall	25
6/4/2022				
6/4/2022	19310300 - 043CF	Classroom Faucet	Classroom 16 W Wall	7
6/4/2022	19310300 - 044DW	Bubbler	Hallway outside of room 16	3
6/4/2022	19310300 - 045DW	Bubbler	Classroom 14, West Wall	17
6/4/2022	19310300 - 046CF	Classroom Faucet	Classroom 14, West Wall	42
6/4/2022	19310300 - 047DW	Bubbler	Classroom 11, West Wall	ND
6/4/2022	19310300 - 048CF	Classroom Faucet	Classroom 11, West Wall	4
6/4/2022	19310300 - 049DW	Bubbler	Hallway outside of room 10	ND
6/4/2022	19310300 - 050WB	Bottle Filler	Hallway outside of room 10	ND
6/4/2022	19310300 - 051CF	Classroom Faucet	Classroom 10, NW	47
6/4/2022	19310300 - 052CF	Classroom Faucet	Classroom 10, SE	6
6/4/2022	19310300 - 053CF	Classroom Faucet	Classroom 8, West Wall	7
6/4/2022	19310300 - 054CF	Classroom Faucet	Classroom 7, West Wall	4
6/4/2022	19310300 - 055BF	Bathroom Faucet	Bathroom, S of room 7	ND
6/4/2022	19310300 - 056BF	Bathroom Faucet	2nd Bathroom, S of room 7	ND
6/4/2022	19310300 - 057SF	Staff/Office Faucet	Staff room	ND
6/4/2022	19310300 - 058WC	Chiller	Staff room East End	ND

Kraxberger Middle School
Water Sampling Tables

6/4/2022	19310300 - 059NS	Nurses Faucet	Health room	2
6/4/2022	19310300 - 060BF	Bathroom Faucet	W of Conference room	ND
6/4/2022	19310300 - 061CF	Classroom Faucet	Classroom 6 East Wall	7
6/4/2022	19310300 - 062DW	Bubbler	Classroom 6 East Wall	1
6/4/2022	19310300 - 063CF	Classroom Faucet	Classroom 5 East Wall	4
6/4/2022	19310300 - 064DW	Bubbler	Classroom 5 East Wall	ND
6/4/2022	19310300 - 065BF	Bathroom Faucet	Bathroom Girls, E of room 10	2
6/4/2022	19310300 - 066BF	Bathroom Faucet	Bathroom Boys, E of room 10	3
6/4/2022	19310300 - 067BF	Bathroom Faucet	Bathroom, W of room 4	ND
6/4/2022	19310300 - 068BF	Bathroom Faucet	Bathroom, W of room 4	2
6/4/2022	19310300 - 069CF	Classroom Faucet	Classroom 4, South Wall	3
6/4/2022	19310300 - 070DW	Bubbler	Classroom 4, South Wall	ND
6/4/2022	19310300 - 071CF	Classroom Faucet	Classroom 3, South Wall	2
6/4/2022	19310300 - 072DW	Bubbler	Classroom 3, South Wall	1
6/4/2022	19310300 - 073DW	Bubbler	Classroom 2 SE Wall	1
6/4/2022	19310300 - 074CF	Classroom Faucet	Classroom 2 SE Wall	4
6/4/2022	19310300 - 075DW	Bubbler	Classroom 1 SE Wall	2
6/11/2022	19310300 - 076CF	Classroom Faucet	Classroom 1 SE Wall	4
6/16/2022	19310300 - 077BF	Bathroom Faucet	East of Room 24	8
9/2/2022	19310300 - 013SF - 2	Staff/Office Faucet	Library office, W wall	9
9/2/2022	19310300 - 023CF - 2	Classroom Faucet	Classroom 24	18
9/2/2022	19310300 - 025CF - 2	Classroom Faucet	Classroom 26	235
9/2/2022	19310300 - 033BF - 2	Bathroom Faucet	Bathroom North of Classroom 22	4
9/2/2022	19310300 - 037BF - 2	Bathroom Faucet	Bathroom Girls North of Classroom 9	6
9/2/2022	19310300 - 038BF - 2	Bathroom Faucet	Classroom 13 East Wall	14
9/2/2022	19310300 - 040CF - 2	Classroom Faucet	Classroom 15 East Wall	ND
9/2/2022	19310300 - 051CF - 2	Classroom Faucet	Classroom 10 NW Wall	2

Gladstone High School Water Sampling Table
High School and Associated Field Buildings

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15			
6/11/2022	19310400 - 001NS	nurses sink	Room J108, NE Corner	9			
6/11/2022	19310400 - 002BF	Bathroom Faucet	Room J101, NE	ND			
6/11/2022	19310400 - 003SF	Staff Faucet	Room J102, NE	16			
6/11/2022	19310400 - 004BF	Bathroom Faucet	East of Room J102	1			
6/11/2022	19310400 - 005BF	Bathroom Faucet	South of Room J108	ND			
6/11/2022	19310400 - 006SF	Staff Faucet	Room J120, East	ND			
6/11/2022	19310400 - 007DW	Bubbler	Hallway, South of Room J116	ND			
6/11/2022	19310400 - 008DW	Bubbler	Hallway, South of Room J115	ND			
6/11/2022	19310400 - 009DW	Bubbler	Lower Gym, SE Wall, Left	ND			
6/11/2022	19310400 - 010DW	Bubbler	Lower Gym, SE Wall, Right	12			
6/11/2022	19310400 - 011DW	Bubbler	North of Room H108	ND			
6/16/2022	19310400 - 012BF	Bathroom Faucet	and Girls Locker Room	5			
6/11/2022	19310400 - 013BF	Bathroom Faucet	and Girls Locker Room	2			
6/11/2022	19310400 - 014DW	Bubbler	Girls Locker Room, Sout Wall, Left	4			
6/11/2022	19310400 - 015DW	Bubbler	Girls Locker Room, Sout Wall, Right	1			
6/11/2022	19310400 - 016DW	Bubbler	Main Gym, SE	15			
6/11/2022	19310400 - 017IM	Ice Machine	West of Room H127, N Wall	1			
6/11/2022	19310400 - 018DW	Bubbler	Room H127, N Wall	1			
6/11/2022	19310400 - 019BF	Bathroom Faucet	NW of Room H127	3			
6/11/2022	19310400 - 020BF	Bathroom Faucet	NE of Room H127	2			
6/11/2022	19310400 - 021DW	Bubbler	Room H135, W Wall	ND			
6/11/2022	19310400 - 022DW	Bubbler	Room H135, W Wall	ND			
6/11/2022	19310400 - 023DW	Bubbler	Boys Locker Room, S Wall, Left	ND			
6/16/2016	19310400-024DW		Boys Locker Room, S Wall, Right	Not Sampled			

Gladstone High School Water Sampling Table
High School and Associated Field Buildings

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15			
6/11/2022	19310400 - 025BF	Sink	North of Boys Locker Room	2			
6/11/2022	19310400 - 026BF	Sink	North of Girls Locker Room	2			
6/11/2022	19310400 - 027SF	Sink	North of Main Gym	3			
6/11/2022	19310400 - 028SF	Sink	SW Corner of Cafeteria	4			
6/11/2022	19310400 - 029DW	Bubbler	Cafeteria, East End, Left	ND			
6/11/2022	19310400 - 030WB	Bottle Filler	Cafeteria, East End, Right	ND			
6/11/2022	19310400 - 031OT	Other	Kitchen, Handwash Sink	3			
6/11/2022	19310400 - 032OT	Other	West End, Dishwasher Sink	3			
6/11/2022	19310400 - 033SF	Sink	Center, Handwash Sink	3			
6/11/2022	19310400 - 034OT	Other	Center, Right, Dishwash Sink	1			
6/11/2022	19310400 - 035OT	Other	Center, Left, Dishwash Sink	1			
6/11/2022	19310400 - 036IM	Ice Machine	Kitchen, SE Corner	ND			
6/11/2022	19310400 - 037SF	Staff Faucet	Kitchen, Center	3			
6/11/2022	19310400 - 038KF	Kitchen Faucet	Kitchen, North Wall	2			
6/11/2022	19310400 - 039OT	Other	Kitchen, East Center, Pot Filler	2			
6/11/2022	19310400 - 040KF	Kitchen Faucet	Kitchen, East Wall	5			
6/11/2022	19310400 - 041SF	Staff Faucet	Kitchen, East End	1			
6/11/2022	19310400 - 043BF	Bathroom Faucet	Room G112	5			
6/11/2022	19310400 - 044BF	Bathroom Faucet	Room G110	2			
6/11/2022	19310400 - 045CF	Classroom Faucet	Room G111	6			
6/11/2022	19310400 - 046BF	Bottle Filler	Room F108, West Wall, Left	1			
6/11/2022	19310400 - 047CF	Classroom Faucet	Room F108, West Wall, Right	1			
6/11/2022	19310400 - 048DW	Bubbler	Hallway North of Kitchen, Left	ND			
6/11/2022	19310400 - 049DW	Bubbler	Hallway North of Kitchen, Right	ND			

Gladstone High School Water Sampling Table
High School and Associated Field Buildings

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15			
6/11/2022	19310400 - 050KF	Kitchen Faucet	Room F103, West Wall, Left	1			
6/11/2022	19310400 - 051KF	Kitchen Faucet	Room F103, West Wall, Right	2			
6/11/2022	19310400 - 052OT	Other	Room F103, South of Wall, Center	4			
6/11/2022	19310400 - 053BF	Bottle Filler	Room F103, Southeast Corner	4			
6/11/2022	19310400 - 054KF	Kitchen Faucet	Room F103, East Wall, Far Right	2			
6/11/2022	19310400 - 055KF	Kitchen Faucet	Room F103, East Wall, Left of 054KF	ND			
6/11/2022	19310400 - 056KF	Kitchen Faucet	Room F103, East Wall, Left of 055KF	2			
6/11/2022	19310400 - 057KF	Kitchen Faucet	Room F103, East Wall, Far Left	ND			
6/11/2022	19310400 - 058SF	Staff Faucet	Room G105, NE Corner	10			
6/11/2022	19310400 - 059DW	Bubbler	North of Room G105, Left	ND			
6/11/2022	19310400 - 060WB	Bottle Filler	North of Room G105, Right	ND			
6/11/2022	19310400 - 061BF	Bathroom Faucet	North of Room A109, East End	ND			
6/11/2022	19310400 - 062BF	Bathroom Faucet	South of Room D101, across the hall	ND			
6/11/2022	19310400 - 063SF	Staff Faucet	East End of Room A108	4			
6/11/2022	19310400 - 064SF	Staff Faucet	Center Library	9			
6/11/2022	19310400 - 065BF	Bathroom Faucet	North of Room D103	ND			
6/11/2022	19310400 - 066BF	Bathroom Faucet	North of Room D103, N of 065BF	ND			
6/11/2022	19310400 - 067SF	Staff Faucet	East of Room A104, North Side	1			
6/11/2022	19310400 - 068CF	Classroom Faucet	West of Room C136	9			
6/11/2022	19310400 - 069CF	Classroom Faucet	Room C134 East Wall, Center	ND			
6/11/2022	19310400 - 070CF	Classroom Faucet	Room C134 North East Corner	ND			
6/11/2022	19310400 - 071CF	Classroom Faucet	Room C129, East End	ND			
6/11/2022	19310400 - 072CF	Classroom Faucet	Room C123, East End, Center	2			
6/11/2022	19310400 - 073CF	Classroom Faucet	Room C123, NE Corner	ND			

Gladstone High School Water Sampling Table
High School and Associated Field Buildings

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15			
6/11/2022	19310400 - 074CF	Classroom Faucet	Room C123, West End, Center	1			
6/11/2022	19310400 - 075CF	Classroom Faucet	Room C112, SW Corner	6			
6/11/2022	19310400 - 076CF	Classroom Faucet	Room C106, East Wall, Center	12			
6/11/2022	19310400 - 077BF	Bathroom Faucet	East of Room C106, Right	4			
6/11/2022	19310400 - 078BF	Bathroom Faucet	East of Room C106, Left	4			
6/11/2022	19310400 - 079DW	Bubbler	Hallway North of C105	1			
6/11/2022	19310400 - 080BF	Bathroom Faucet	West of Room C123, Girls, South	2			
6/11/2022	19310400 - 081BF	Bathroom Faucet	West of Room C123, Girls, North	3			
6/11/2022	19310400 - 082BF	Bathroom Faucet	Area C102, SE Corner	3			
6/11/2022	19310400 - 083BF	Bathroom Faucet	Area C102, SE Corner	1			
6/11/2022	19310400 - 084BF	Bathroom Faucet	Area C102, SE Corner	ND			
6/11/2022	19310400 - 085BF	Bathroom Faucet	Area C102, SW Corner	2			
6/11/2022	19310400 - 086BF	Bathroom Faucet	Area C102, SW Corner	3			
6/11/2022	19310400 - 087BF	Bathroom Faucet	Area C102, SW Corner	2			
6/11/2022	19310400 - 088BF	Bathroom Faucet	West of 087BF	ND			
6/11/2022	19310400 - 089WB	Bottle Filler	Area C102, SW Corner	ND			
6/11/2022	19310400 - 090DW	Bubbler	Area C102, SW Corner	ND			
6/11/2022	19310400 - 091DW	Bubbler	Area C102, SW Corner	ND			
6/11/2022	19310400 - 092CF	Classroom Faucet	West of Room B106	15			
6/11/2022	19310400 - 093CF	Classroom Faucet	Room B109	2			
6/11/2022	19310400 - 094SF	Staff Faucet	Room B110	2			
6/11/2022	19310400 - 095BF	Bathroom Faucet	Hallway South of Room 116 & 115	ND			
6/11/2022	19310400 - 096 Hand	Staff Faucet	Additional Sink in Student Store	9			

Gladstone High School Water Sampling Table
 High School and Associated Field Buildings

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15			
			<u>Baseball Field</u>				
6/16/2022	19310402 - 001KS	Kitchen Faucet	Baseball Snack Shack Sink	1			
6/16/2022	19310402 - 002OS	Outside Spigot	Baseball Snack Shack outside Spigot	ND			

Gladstone High School Water Sampling Table
 High School and Associated Field Buildings

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15			
			<u>Woodshop/Robotics</u>				
6/11/2022	19310401 - 001BF	Bathroom Faucet	Between Rm K101 & K102, W Center, L	2			
6/11/2022	19310401 - 002BF	Bathroom Faucet	Between Rm K101 & K102, W Center, R	ND			
6/11/2022	19310401 - 003CF	Classroom Faucet	Room K102, N Wall	4			
6/11/2022	19310401 - 004DW	Bubbler	Room K102, N Wall, L	ND			
6/11/2022	19310401 - 005DW	Bubbler	Room K102, N Wall, R	ND			
6/11/2022	19310401 - 006DW	Bubbler	Room K101, S Wall, R	ND			
6/11/2022	19310401 - 007DW	Bubbler	Room K101, S Wall, L	ND			
6/11/2022	19310401 - 008CF	Classroom Faucet	Room K101, S Wall	ND			

Gladstone High School Water Sampling Table
High School and Associated Field Buildings

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15			
			<u>Field Areas GHS</u>				
6/16/2022	19310403 - 001BF	Bathroom Faucet	NE Bldg, Girls Bathroom	ND			
6/16/2022	19310403 - 002BF	Bathroom Faucet	NE Bldg, Girls Bathroom, N	ND			
6/16/2022	19310403 - 003BF	Bathroom Faucet	NE Bldg, Boys Bathroom, S	1			
6/16/2022	19310403 - 004BF	Bathroom Faucet	NE Bldg, Boys Bathroom, N	ND			
6/16/2022	19310403-005IM	Ice Machine	NE Bldg, Track Side, NW Corner	not sampled			
6/16/2022	19310403 - 006KS	Kitchen Sink	NE Bldg, Track Side, SW Corner	4			
6/16/2022	19310403 - 009KS	Kitchen Sink	N End of Covered Stadium	8			
6/16/2022	19310403 - 008DW	Bubbler	Shack, Corner Closest to Track	ND			
6/16/2022	19310403 - 007OS	Outside Spigot	NW Bldg, Snack Shack Kitchen Sink	6			
6/16/2022	19310403 - 010OS	Outside Spigot	NW of Snack Shack, Parking Area	ND			
6/16/2022	19310403 - 011OS	Outside Spigot	Area, N Corner of Bldg.	2			

Gladstone District Office
Water Sampling Table

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15
6/11/2022	19310100 - 001BF	Bathroom Faucet	Bathroom by Custodial Closet	9
6/11/2022	19310100 - 002BF	Bathroom Faucet	Nearest Main Hallway	4
6/11/2022	19310100 - 003KF	Kitchen Faucet	Lunchroom Sink	3
6/11/2022	19310100 - 004OT	Filtered Faucet	Filtered Cold Tap at Sink	2

Gladstone Center For Children and Families
Water Sampling Table

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15
6/11/2022	19310500 - 001NS	Nurses Sink	West of Main Office	ND
6/11/2022	19310500 - 002BF	Bathroom Faucet	West of Nurses Sink	ND
6/11/2022	19310500 - 003BF	Bathroom Faucet	North of 002 BF	ND
6/11/2022	19310500 - 004BF	Bathroom Faucet	East of 003 BF	ND
6/11/2022	19310500 - 005BF	Bathroom Faucet	South of Room K3	ND
6/11/2022	19310500 - 006BF	Bathroom Faucet	South of Room K3	ND
6/11/2022	19310500 - 007BF	Bathroom Faucet	South of Room K2	ND
6/11/2022	19310500 - 008SF	Staff Faucet	Room Southwest of Office	ND
6/11/2022	19310500 - 009CF	Classroom Faucet	K1, South	ND
6/11/2022	19310500 - 010DW	Bubbler	K1, Center	2
6/11/2022	19310500 - 011CF	Classroom Faucet	K1, North	ND
6/11/2022	19310500 - 012CF	Classroom Faucet	K2, South	ND
6/11/2022	19310500 - 013DW	Bubbler	K2, Center	6
6/11/2022	19310500 - 014CF	Classroom Faucet	K2, North	1
6/11/2022	19310500 - 015CF	Classroom Faucet	K3, South	ND
6/11/2022	19310500 - 016DW	Bubbler	K3, Center	3
6/11/2022	19310500 - 017CF	Classroom Faucet	K3 North	1

Gladstone Center For Children and Families
Water Sampling Table

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15
6/11/2022	19310500 - 018CF	Classroom Faucet	K4, East	ND
6/11/2022	19310500 - 019DW	Bubbler	K4, Center	4
6/11/2022	19310500 - 020CF	Classroom Faucet	K4, West	ND
6/11/2022	19310500 - 021CF	Classroom Faucet	K5, East	ND
6/11/2022	19310500 - 022DW	Classroom Faucet	K5, Center	22
6/11/2022	19310500 - 023CF	Bubbler	K5, West	ND
6/11/2022	19310500 - 024CF	Faucet	K6, East	ND
6/11/2022	19310500 - 025DW	Bubbler	K6, center	70
6/11/2022	19310500 - 026CF	Faucet	K6, West	4
6/11/2022	19310500 - 027IM	Ice Machine	Kitchen Ice Machine, North Wall	ND
6/11/2022	19310500 - 028OT	Other	Kitchen Pot Filler N Wall	4
6/11/2022	19310500 - 029KF	Kitchen Faucet	Kitchen east Wall North	1
6/11/2022	19310500 - 030KF	Kitchen Faucet	Kitchen East Wall South	ND
6/11/2022	19310500 - 031KF	Kitchen Faucet	Kitchen South Wall East	3
6/11/2022	19310500 - 032KF	Kitchen Faucet	Kitchen South Wall West	23
6/11/2022	19310500 - 033OT	Sprayer	Kitchen Sprayer East End	ND
6/11/2022	19310500 - 034KF	Kitchen Faucet	Kitchen Northwest	3

Gladstone Center For Children and Families
Water Sampling Table

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15
6/11/2022	19310500 - 035KF	Kitchen Faucet	Kitchen Northwest	2
6/11/2022	19310500 - 036OT	Sprayer	Kitchen Sprayer West End	2
6/11/2022	19310500 - 037SF	Staff Faucet	Dental Room	ND
6/11/2022	19310500 - 038DW	Bubbler	Hallway East of Dental Room North	ND
6/11/2022	19310500 - 039WB	Bottle Filler	Hallway East of Dental Room	ND
6/11/2022	19310500 - 040DW	Bubbler	Hallway East of Dental Room South	ND
6/11/2022	19310500 - 041OT	Other	Open Area	3
6/11/2022	19310500 - 042BF	Bathroom Faucet	North of Head Start North	2
6/11/2022	19310500 - 043BF	Bathroom Faucet	North of Head Start South	ND
6/11/2022	19310500 - 044BF	Bathroom Faucet	East of ESD 7, North	ND
6/11/2022	19310500 - 045BF	Bathroom Faucet	East of ESD 7, South	1
6/11/2022	19310500 - 046CF	Classroom Faucet	ESD 7, North	ND
6/11/2022	19310500 - 047DW	Bubbler	ESD 7, Center	4
6/11/2022	19310500 - 048CF	Classroom Faucet	ESD 7, South	ND
6/11/2022	19310500 - 049CF	Classroom Faucet	ESD 8, North	1
6/11/2022	19310500 - 050DW	Bubbler	ESD 8, Center	5
6/11/2022	19310500 - 051CF	Classroom Faucet	ESD 8, South	ND

Gladstone Center For Children and Families
Water Sampling Table

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15
6/11/2022	19310500 - 052BF	Bathroom Faucet	East of Head Start 9, North	ND
6/11/2022	19310500 - 053BF	Bathroom Faucet	East of Head Start 9, South	2
6/11/2022	19310500 - 054CF	Classroom Faucet	East of Head Start 9, North	ND
6/11/2022	19310500 - 055DW	Bubbler	East of Head Start 9, Center	33
6/11/2022	19310500 - 056CF	Classroom Faucet	East of Head Start 9, South	3
6/11/2022	19310500 - 057CF	Classroom Faucet	Head Start 10, North	2
6/11/2022	19310500 - 058DW	Bubbler	Head Start 10 Center	36
6/11/2022	19310500 - 059CF	Classroom Faucet	Head Start 10, South	2
6/11/2022	19310500 - 060OS	Spigot Outside	Outside West of Indoor Playground	1

Gladstone Center for Children Families
Health Clinic
Water Sampling Table

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD ppb EPA MCL: 15
6/16/2022	19310501 - 001BF	Bathroom Faucet	B105 Drinking Water Fountain	6
6/16/2022	19310501 - 002BF	Bathroom Faucet	A106 Drinking Water Fountain	ND
6/16/2022	19310501 - 003CF	Classroom Faucet	B111 Classroom Faucet, N	3
6/16/2022	19310501 - 004CF	Classroom Faucet	B111 Classroom Faucet, S	12
6/16/2022	19310501 - 005CF	Classroom Faucet	B117 Drinking Water Fountain	6
6/16/2022	19310501 - 006CF	Classroom Faucet	B115 Classroom Faucet, E	17
6/16/2022	19310501 - 007CF	Classroom Faucet	B115 Classroom Faucet, W	22
6/16/2022	19310501 - 008BF	Bathroom Faucet	B114 Drinking Water Fountain	2
6/16/2022	19310501 - 009BF	Bathroom Faucet	B113 Drinking Water Fountain	4
6/16/2022	19310501 - 010CF	Classroom Faucet	B112 Classroom Faucet, W Wall, N	ND
6/16/2022	19310501 - 011CF	Classroom Faucet	B112 Classroom Faucet, W Wall, S	24
6/16/2022	19310501 - 012KF	Kitchen Faucet	A107 Kitchen/Food Prep Sink	3
6/16/2022	19310501 - 013BF	Bathroom Faucet	A105 Drinking Water Fountain	ND
6/16/2022	19310501 - 014OT	Other	A104 Exam Sink	28
6/16/2022	19310501 - 015OT	Other	A103 Exam Sink	32
6/16/2022	19310501 - 016OT	Other	A102 Exam Sink	15
6/16/2022	19310501 - 017BF	Bubbler	A101 Drinking Water Fountain	1
6/16/2022	19310501 - 018OT	Other	A111 Exam Sink	4
6/16/2022	19310501 - 019OT	Other	A110 Exam Sink	5
6/16/2022	19310501 - 020OT	Other	A109 Exam Sink	2
6/16/2022	19310501 - 021OT	Other	A108 Exam Sink, W Wall, S	32
6/16/2022	19310501 - 022OT	Other	A108 Exam Sink, W Wall, N	30
6/16/2022	19310501 - 023CS	Classroom Faucet	B116 Classroom Sink, W Wall	6
6/16/2022	19310501 - 024BF	Bathroom Faucet	B114 Bathroom Faucet, S Wall	9

John Wetten Elementary School
250 East Exeter
Gladstone, Oregon 97027

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD EPA MCL: 15 ppb
6/4/2022	19310200 - 001SF	Bubbler	Staff Room, S of Main Office	11
6/4/2022	19310200 - 002BF	Bathroom Faucet	SE Corner of Staff Room	2
6/4/2022	19310200 - 003BF	Bathroom Faucet	SE Wall of Staff Room	ND
6/4/2022	19310200 - 004DW	Fountain	Room 8 West Wall	2
6/4/2022	19310200 - 005CF	Classroom Faucet	Room 8 West Wall	2
6/4/2022	19310200 - 006DW	Bubbler	Room 7, N wall	4
6/4/2022	19310200 - 007CF	Classroom Faucet	Room 7, N wall	2
6/4/2022	19310200 - 008DW	Bubbler	Room 6, N wall	ND
6/4/2022	19310200 - 009CF	Classroom Faucet	Room 6, N wall	1
6/4/2022	19310200 - 010DW	Bubbler	Room 5, E side	2
6/4/2022	19310200 - 011CF	Classroom Faucet	Room 5, E side	4
6/4/2022	19310200 - 012DW	Bubbler	Room 4, W side	ND
6/4/2022	19310200 - 013CF	Classroom Faucet	Room 4, W side	3
6/4/2022	19310200 - 014DW	Bubbler	Room 3, E side	1
6/4/2022	19310200 - 015CF	Classroom Faucet	Room 3, E side	11
6/4/2022	19310200 - 016DW	Bubbler	Room 2, W side	3
6/4/2022	19310200 - 017CF	Classroom Faucet	Room 2, W side	ND
6/4/2022	19310200 - 018BF	Bathroom Faucet	Bathroom, N of Room 2	ND
6/4/2022	19310200 - 019BF	Bathroom Faucet	Bathroom, N of Room 5	ND
6/4/2022	19310200 - 020BF	Bathroom Faucet	Bathroom, S of Room 9	ND
6/4/2022	19310200 - 021DW	Bubbler	Room 9, W wall	28

John Wetten Elementary School
250 East Exeter
Gladstone, Oregon 97027

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD EPA MCL: 15 ppb
6/4/2022	19310200 - 022CF	Classroom Faucet	Room 9, W wall	7
6/4/2022	19310200 - 023DW	Bubbler	Room 10, W wall	55
6/4/2022	19310200 - 024CF	Classroom Faucet	Room 10, W wall	18
6/4/2022	19310200 - 025DW	Bubbler	Hallway, N of small Courtyard	ND
6/4/2022	19310200 - 026WB	Water Bottle Fill	Hallway, N of small Courtyard	ND
6/4/2022	19310200 - 027BF	Bathroom Faucet	Bathroom, N of Room 10	2
6/4/2022	19310200 - 028BF	Bathroom Faucet	Bathroom, NE of Room 10	ND
6/4/2022	19310200 - 029BF	Bathroom Faucet	W of Main Office, Office Work Room	ND
6/4/2022	19310200 - 030NS	Nurses Office Sink	Health Room, W of Main Office	7
6/4/2022	19310200 - 031BF	Bathroom Faucet	Health Room, W of Main Office	ND
6/4/2022	19310200 - 032IM	Ice Machine	Kitchen, S end	ND
6/4/2022	19310200 - 033BF	Bathroom Faucet	Kitchen, SE corner	ND
6/4/2022	19310200 - 034OT	Pot Filler	Kitchen, center, pot filler faucet	3
6/4/2022	19310200 - 035OT	Sprayer	Kitchen, center, sprayer	12
6/4/2022	19310200 - 036SF	Staff/Office Faucet	Kitchen, E side, center	ND
6/4/2022	19310200 - 037KF	Kitchen Faucet	Kitchen, NE end, R sink	2
6/4/2022	19310200 - 038KF	Kitchen Faucet	Kitchen, NE end, L sink	ND
6/4/2022	19310200 - 039OT	Sprayer	Kitchen, NE end, sink sprayer	ND
6/16/2022	19310200 - 040DW	Bubbler	Cafeteria, S Central Wall (High)	7
6/16/2022	19310200 - 041DW	Bubbler	Cafeteria, S Central Wall (Low)	2
6/4/2022	19310200 - 042SF	Staff/Office Faucet	Room SE of Cafeteria	ND
6/4/2022	19310200 - 043CF	Classroom Faucet	Room 36, E end, N wall	ND
6/4/2022	19310200 - 044DW	Bubbler	Room 36, E end, N wall	8
6/4/2022	19310200 - 047DW	Bubbler	Room 35, W end, N wall	4

John Wetten Elementary School
250 East Exeter
Gladstone, Oregon 97027

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD EPA MCL: 15 ppb
6/4/2022	19310200 - 048CF	Classroom Faucet	Room 35, W end, N wall	2
6/4/2022	19310200 -049DW	Bubbler	Room 33, West End, South Wall	20
6/4/2022	19310200 -050CF	Classroom Faucet	Room 33, West End, South Wall	3
6/4/2022	19310200 -051DW	Bubbler	Room 32, E end, S wall	6
6/4/2022	19310200 - 052CF	Classroom Faucet	Room 32, E end, S wall	4
6/16/2022	19310200 - 053DW	Bubbler	Hallway, Between Rooms 31 & 32	3
6/4/2022	19310200 - 054BF	Bathroom Faucet	Restroom, E of Room 32	ND
6/4/2022	19310200 - 055BF	Bathroom Faucet	Restroom, W of Room 31	ND
6/4/2022	19310200 - 056DW	Bubbler	Room 31, W end, S wall	6
6/4/2022	19310200 - 057CF	Classroom Faucet	Room 31, W end, S wall	2
6/4/2022	19310200 - 058DW	Bubbler	Room 30, E end, S wall	2
6/4/2022	19310200 - 059CF	Classroom Faucet	Room 30, E end, S wall	1
6/4/2022	19310200 - 060DW	Bubbler	Room 28, W end, S wall	2
6/4/2022	19310200 - 061CF	Classroom Faucet	Room 28, W end, S wall	2
6/4/2022	19310200 - 062CF	Classroom Faucet	Room 29, W end, N wall	2
6/4/2022	19310200 - 063DW	Bubbler	Room 29, W end, N wall	3
6/4/2022	19310200 - 064CF	Classroom Faucet	Room 27, W end, N wall	2
6/4/2022	19310200 - 065DW	Bubbler	Room 27, W end, N wall	4
6/4/2022	19310200 - 066BF	Bathroom Faucet	Outside Gym, N end, W wall	6
6/4/2022	19310200 - 067BF	Bathroom Faucet	Outside Gym, N end, W wall	10
6/4/2022	19310200 - 068DW	Bubbler	Room 26, SE corner	3
6/4/2022	19310200 - 069CF	Classroom Faucet	Room 26, SE corner	6
6/4/2022	19310200 - 070CF	Classroom Faucet	Room 25, NE corner	1
6/4/2022	19310200 - 071DW	Bubbler	Room 25, NE corner	1

John Wetten Elementary School
250 East Exeter
Gladstone, Oregon 97027

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD EPA MCL: 15 ppb
6/4/2022	19310200 - 072BF	Bathroom Faucet	Restroom, E of room 25	ND
6/4/2022	19310200 - 073DW	Bubbler	Room 24, SW Corner	51
6/4/2022	19310200 - 074CF	Classroom Faucet	Room 24, SW corner	2
6/4/2022	19310200 - 075DW	Bubbler	Room 23, SE corner	1
6/4/2022	19310200 - 076CF	Classroom Faucet	Room 23, SE corner	8
6/4/2022	19310200 - 077DW	Bubbler	Room 22, SE corner	11
6/4/2022	19310200 - 078CF	Classroom Faucet	Room 22, SE corner	6
6/4/2022	19310200 - 079DW	Bubbler	Room 21B, SE corner	2
6/4/2022	19310200 - 080CF	Classroom Faucet	Room 21B, SE corner	2
6/4/2022	19310200 - 081CF	Classroom Faucet	Room 21A, W wall	3
6/4/2022	19310200 - 082DW	Bubbler	Room 21A, W wall	3
6/16/2022	19310200 - 083DW	Bubbler	Hallway, W of Rom 21A, right side	8
6/16/2022	19310200 - 084DW	Bubbler	Hallway, W of Rom 21A, left side	3
6/16/2022	19310200 - 085BF	Bottle Filler	Restroom, W of Room 21A, right side	ND
6/16/2022	19310200 - 086BF	Bottle Filler	Restroom, W of Room 21A, left side	1
6/16/2022	19310200 - 087CF	Sink	Room 19, E Wall	4
6/16/2022	19310200 - 088DW	Bubbler	Room 19, E Wall	8
6/4/2022	19310200 - 089CF	Classroom Faucet	Room 20, W wall	2
6/4/2022	19310200 - 090DW	Bubbler	Room 20, W wall	6
6/4/2022	19310200 - 091CF	Classroom Faucet	Room 18, W wall	2
6/4/2022	19310200 - 092DW	Bubbler	Room 18, W wall	3
6/16/2022	19310200 - 093CF	Sink	Room 17, E Wall	10
6/16/2022	19310200 - 094DW	Bubbler	Room 17, E Wall	7
6/4/2022	19310200 - 095DW	Bubbler	Room 16 B, N wall	1

John Wetten Elementary School
250 East Exeter
Gladstone, Oregon 97027

DATE	SAMPLE NUMBER	FAUCET TYPE	LOCATION	LEAD EPA MCL: 15 ppb
6/4/2022	19310200 - 096CF	Classroom Faucet	Room 16 B, N wall	ND
6/4/2022	19310200 - 097DW	Bubbler	Room 16A, N wall	1
6/4/2022	19310200 - 098CF	Classroom Faucet	Room 16A, N wall	2
6/16/2022	19310200 - 099DW	Bubbler	Room 15, N Wall	9
6/16/2022	19310200 - 100CF	Sink	Room 15, N Wall	5
6/16/2022	19310200 - 101DW	Bubbler	Room 14, N wall	2
6/16/2022	19310200 - 102CF	Classroom Faucet	Room 14, N wall	2
6/16/2022	19310200 - 103DW	Bubbler	Room 13, N wall	5
6/16/2022	19310200 - 104CF	Classroom Faucet	Room 13, N wall	2
6/16/2022	19310200 -105BF	Bathroom Faucet	W of Room 8	2
6/16/2022	19310200 - 106OT	Dishwashing Sink	Kitchen, dishwashing sink, NE corner	ND
6/16/2022	19310200 - 107CF	Classroom Faucet	W of Library, 107 on map.	2
9/2/2022	19310200 - 024 CF-2	Classroom Faucet	Room 10, W wall	32
9/2/2022	19310200 - 073DW-2	Bubbler	Room 24, SW corner	15